



789 N. Dixboro Rd. Ann Arbor, MI 48105, USA
1-800.NSF.MARK | +1-734.769.8010 | www.nsf.org

EVALUATION REPORT

Send To: 0B020

Mr. Seyfettin Kilinc
Subor Boru Sanayi Ve Ticaret A.S.
Ahmetler Mahallesi
Karapurcek 54430 Sakarya
Turkey

Facility: 0B021

Subor Boru Sanayi Ve Ticaret A.S.
Ahmetler Mahallesi
Karapurcek 54430 Sakarya
Turkey

Result	PASS	Report Date	05-DEC-2024
Customer Name	Subor Boru Sanayi Ve Ticaret A.S.		
Tested To	NSF/ANSI/CAN 61		
Description	Subor GRP Pipe 300mm ID x 6" L Pipe		
Trade Designation	Subor GRP Pipe		
Test Type	Annual Collection		
Job Number	A-00474325		
Project Number	W0870364		
Project Manager	Siska Amalia		

Thank you for having your product tested by NSF.

Please contact your Project Manager if you have any questions or concerns pertaining to this report.

Report Authorization

Abbie Batog - Senior Manager Commercial Water

Date

05-DEC-2024



General Information

Standard: NSF/ANSI/CAN 61
Monitor Code: B
Physical Description of Sample: 300mm ID x 6" L Pipe
Tested DCC Number: PM03529
Trade Designation/Model Number: Subor GRP Pipe

Sample Id: S-0002166072
Description: Sample exposed at 23C and pH 5
Sampled Date: 11/15/2024
Received Date: 10/16/2024

Normalization Information:							
Date exposure completed:	15-NOV-2024	Calculated N1:	0.66	Field Exposure Time:	16 hours	Lab Exposure Time:	16 hours
Field Surface Area:	20.3 in2	Lab Surface Area:	37.0 in2	Constant N2:	1	Misc. Factor:	1
Field Static Volume:	1 L	Lab Static Volume:	1.20 L	Calculated NFm:	1.00		
Compound Reference Key:	SPAC						

Testing Parameter	Sample	Control	Result	Normalized Result	Units
Ann Arbor Chemistry Lab					
* Standard 61 Additives LAB SUM TEST Code					
External Note:		Product was glued to glass.			
Metals I in water by ICPMS (Ref: EPA 200.8)					
Aluminum	ND(10)	ND(10)	ND(10)	ND(6.6)	ug/L
Arsenic	ND(1)	ND(1)	ND(1)	ND(0.7)	ug/L
Barium	ND(1)	ND(1)	ND(1)	ND(0.7)	ug/L
Beryllium	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
Bismuth	ND(1)	ND(1)	ND(1)	ND(0.7)	ug/L
Cadmium	ND(0.2)	ND(0.2)	ND(0.2)	ND(0.1)	ug/L
Chromium	ND(1)	ND(1)	ND(1)	ND(0.7)	ug/L
Copper	ND(1)	ND(1)	ND(1)	ND(0.7)	ug/L
Mercury	ND(0.2)	ND(0.2)	ND(0.2)	ND(0.1)	ug/L
Nickel	ND(1)	ND(1)	ND(1)	ND(0.7)	ug/L
Lead	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
Antimony	ND(0.5)	0.6	ND(0.5)	ND(0.3)	ug/L
Selenium	ND(1)	ND(1)	ND(1)	ND(0.7)	ug/L
Tin	1.3	1.9	ND(0.5)	ND(0.33)	ug/L
Strontium	ND(1)	ND(1)	ND(1)	ND(0.7)	ug/L
Thallium	ND(0.2)	ND(0.2)	ND(0.2)	ND(0.1)	ug/L
Zinc	ND(10)	ND(10)	ND(10)	ND(6.6)	ug/L
Silver	ND(1)	ND(1)	ND(1)	ND(0.7)	ug/L
Cobalt in Drinking Water by ICPMS (Ref: EPA 200.8)					
Cobalt	ND(1)	ND(1)	ND(1)	ND(0.7)	ug/L

Sample Id: S-0002166073
Description: Sample exposed at 23C and pH 8
Sampled Date: 11/15/2024
Received Date: 10/16/2024



Sample Id: S-0002166073

Normalization Information:

Date exposure completed:	15-NOV-2024	Calculated N1:	0.67	Field Exposure Time:	16 hours	Lab Exposure Time:	16 hours
Field Surface Area:	20.3 in2	Lab Surface Area:	36.5 in2	Constant N2:	1	Misc. Factor:	1
Field Static Volume:	1 L	Lab Static Volume:	1.20 L	Calculated NFm:	1.00		
Compound Reference Key:	SPAC						

Testing Parameter	Sample	Control	Result	Normalized Result	Units
Ann Arbor Chemistry Lab					
* Acrylonitrile, Acetates and Acrylates by VOC GCMS					
Acrylonitrile	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
Ethyl acetate	ND(1)	ND(1)	ND(1)	ND(0.7)	ug/L
Methyl acrylate	ND(1)	ND(1)	ND(1)	ND(0.7)	ug/L
Ethyl acrylate	ND(1)	ND(1)	ND(1)	ND(0.7)	ug/L
tert-Butyl Acetate	ND(1)	ND(1)	ND(1)	ND(0.7)	ug/L
Methyl methacrylate	ND(1)	ND(1)	ND(1)	ND(0.7)	ug/L
Isobutyl acetate	ND(1)	ND(1)	ND(1)	ND(0.7)	ug/L
n-Butyl acetate	ND(1)	ND(1)	ND(1)	ND(0.7)	ug/L
Butyl acrylate	ND(1)	ND(1)	ND(1)	ND(0.7)	ug/L
Butyl methacrylate	ND(1)	ND(1)	ND(1)	ND(0.7)	ug/L
Methyl Acetate	ND(1)	ND(1)	ND(1)	ND(0.7)	ug/L
* Standard 61 Additives LAB SUM TEST Code					
External Note:	Product was glued to glass.				
Metals I in water by ICPMS (Ref: EPA 200.8)					
Aluminum	ND(10)	ND(10)	ND(10)	ND(6.7)	ug/L
Arsenic	ND(1)	ND(1)	ND(1)	ND(0.7)	ug/L
Barium	ND(1)	ND(1)	ND(1)	ND(0.7)	ug/L
Beryllium	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
Bismuth	ND(1)	ND(1)	ND(1)	ND(0.7)	ug/L
Cadmium	ND(0.2)	ND(0.2)	ND(0.2)	ND(0.1)	ug/L
Chromium	ND(1)	ND(1)	ND(1)	ND(0.7)	ug/L
Copper	ND(1)	ND(1)	ND(1)	ND(0.7)	ug/L
Mercury	ND(0.2)	ND(0.2)	ND(0.2)	ND(0.1)	ug/L
Nickel	ND(1)	ND(1)	ND(1)	ND(0.7)	ug/L
Lead	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
Antimony	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
Selenium	ND(1)	ND(1)	ND(1)	ND(0.7)	ug/L
Tin	2.8	0.97	1.9	1.2	ug/L
Strontium	1	1	ND(1)	ND(0.7)	ug/L
Thallium	ND(0.2)	ND(0.2)	ND(0.2)	ND(0.1)	ug/L
Zinc	ND(10)	ND(10)	ND(10)	ND(6.7)	ug/L
Silver	ND(1)	ND(1)	ND(1)	ND(0.7)	ug/L
BASE/NEUTRAL/ACID EPA METHOD 625 modified Scan for Tentatively Identified C					
No Compounds Detected					
Scan Control Complete	TRUE				
Semivolatile Compounds, Base/Neutral/Acid Target 625 modified, Data Workup					



Sample Id: S-0002166073

Testing Parameter	Sample	Control	Result	Normalized Result	Units
Ann Arbor Chemistry Lab (Continued)					
Pyridine	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Nitrosodimethylamine (N-)	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
N-Nitrosomethylethylamine	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
5-Methyl-2-hexanone (MIAK)	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
1-Methoxy-2-propanol acetate	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
2-Heptanone	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Cyclohexanone	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Nitrosodiethylamine (N-)	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Isobutylisobutyrate	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Aniline	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Phenol	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Di(chloroethyl) ether	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
2-Chlorophenol	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
2,3-Benzofuran	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
1,3-Dichlorobenzene	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
1,4-Dichlorobenzene	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
3-Cyclohexene-1-carbonitrile	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
2-Ethylhexanol	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Benzyl alcohol	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
1,2-Dichlorobenzene	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
bis(2-Chloroisopropyl)ether	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
2-Methylphenol (o-Cresol)	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
N-Methylaniline	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Acetophenone	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
N-Nitrosodi-n-propylamine	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
N-Nitrosopyrrolidine	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
3- and 4-Methylphenol (m&p-Cresol)	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Hexachloroethane	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
2-Phenyl-2-propanol	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
N-Nitrosomorpholine	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Nitrobenzene	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
2,6-Dimethylphenol	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
N-Vinylpyrrolidinone	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
N-Nitrosopiperidine	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Triethylphosphate	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Isophorone	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
2-Nitrophenol	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
2,4-Dimethylphenol	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
bis(2-Chloroethoxy)methane	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
2,4-Dichlorophenol	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Trichlorobenzene (1,2,4-)	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Naphthalene	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
4-Chloroaniline	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
1,1,3,3,-Tetramethyl-2-thiourea	ND(4)	ND(4)	ND(4)	ND(3)	ug/L



Sample Id: S-0002166073

Testing Parameter	Sample	Control	Result	Normalized Result	Units
Ann Arbor Chemistry Lab (Continued)					
Hexachlorobutadiene	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Benzothiazole	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
N-Nitrosodi-n-butylamine	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
4-Chloro-3-methylphenol	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
p-tert-Butylphenol	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
2-Ethylhexyl glycidyl ether	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
2,6-Di-t-butyl-4-methylphenol(BHT)	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Methylnaphthalene, 2-	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Cyclododecane	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
2,4,5-Trichlorophenol	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
2,4,6-trichlorophenol	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
1(3H)-Isobenzofuranone	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
2-Chloronaphthalene	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
2-Nitroaniline	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
1,1'-(1,3-Phenylene)bis ethanone	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
2,6-Di-tert-butylphenol	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Dimethylphthalate	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
1,1'-(1,4-Phenylene)bis ethanone	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Acenaphthylene	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Benzenedimethanol, a,a,a',a'-tetramethyl-1,3-	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
2,6-Dinitrotoluene	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
2,4-Dinitrotoluene	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Benzenedimethanol, a,a,a',a'-Tetramethyl-1,4-	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
2,4-Di-tert-butylphenol	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Dimethyl terephthalate	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Acenaphthene	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Dibenzofuran	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Ethyl-4-ethoxybenzoate	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
4-Nitrophenol	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Cyclododecanone	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Diethyl Phthalate	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
p-tert-Octylphenol	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Fluorene	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
4-Chlorophenylphenylether	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
3-Nitroaniline	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
4-Nitroaniline	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Nitrosodiphenylamine (N-)	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Azobenzene	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
4-Bromophenylphenylether	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Hexachlorobenzene	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Pentachlorophenol	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Phenanthrene	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Anthracene	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Diisobutyl phthalate	ND(2)	ND(2)	ND(2)	ND(1)	ug/L



Sample Id: S-0002166073

Testing Parameter	Sample	Control	Result	Normalized Result	Units
Ann Arbor Chemistry Lab (Continued)					
Dibutyl phthalate	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Diphenyl sulfone	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Hydroxymethylphenylbenzotriazole	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Fluoranthene	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Pyrene	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Butyl benzyl phthalate	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Di(2-ethylhexyl)adipate	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
3,3-Dichlorobenzidine	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Benzo(a)anthracene	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Di(2-ethylhexyl)phthalate	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Chrysene	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Di-n-octylphthalate	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Benzo(b)fluoranthene	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Benzo(k)fluoranthene	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Benzo(a)Pyrene (PAH)	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Dibenzo(a,h)anthracene	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Indeno(1,2,3-cd)pyrene	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Benzo(g,h,i)perylene	ND(2)	ND(2)	ND(2)	ND(1)	ug/L
Cobalt in Drinking Water by ICPMS (Ref: EPA 200.8)					
Cobalt	ND(1)	ND(1)	ND(1)	ND(0.7)	ug/L
* Acrylic Acid, LC/UV					
Acrylic acid	ND(10)	ND(10)	ND(10)	ND(6.7)	ug/L
* Phthalic Acids					
Phthalic Acid	ND(20)	ND(20)	ND(20)	ND(13)	ug/L
Terephthalic Acid	ND(20)	ND(20)	ND(20)	ND(13)	ug/L
Isophthalic Acid	ND(20)	ND(20)	ND(20)	ND(13)	ug/L
Volatile Organic Compounds (Ref: EPA 524.2)					
Dichlorodifluoromethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
Chloromethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
Vinyl Chloride	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
Bromomethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
Chloroethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
Trichlorofluoromethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
Trichlorotrifluoroethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
Methylene Chloride	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
1,1-Dichloroethylene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
trans-1,2-Dichloroethylene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
1,1-Dichloroethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
2,2-Dichloropropane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
cis-1,2-Dichloroethylene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
Chloroform	0.5	ND(0.5)	0.5	0.3	ug/L
Bromochloromethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
1,1,1-Trichloroethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
1,1-Dichloropropene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L



Sample Id: S-0002166073

Testing Parameter	Sample	Control	Result	Normalized Result	Units
Ann Arbor Chemistry Lab (Continued)					
Carbon Tetrachloride	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
1,2-Dichloroethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
Trichloroethylene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
1,2-Dichloropropane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
Bromodichloromethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
Dibromomethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
cis-1,3-Dichloropropene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
trans-1,3-Dichloropropene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
1,1,2-Trichloroethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
1,3-Dichloropropane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
Tetrachloroethylene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
Chlorodibromomethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
Chlorobenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
1,1,1,2-Tetrachloroethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
Bromoform	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
1,1,2,2-Tetrachloroethane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
1,2,3-Trichloropropane	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
1,3-Dichlorobenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
1,4-Dichlorobenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
1,2-Dichlorobenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
Carbon Disulfide	ND(1)	ND(1)	ND(1)	ND(0.7)	ug/L
Methyl-tert-Butyl Ether (MTBE)	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
tert-Butyl ethyl ether	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
Methyl Ethyl Ketone	8	ND(5)	8	5	ug/L
Methyl Isobutyl Ketone	ND(5)	ND(5)	ND(5)	ND(3)	ug/L
Toluene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
Ethyl Benzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
m+p-Xylenes	ND(1)	ND(1)	ND(1)	ND(0.7)	ug/L
o-Xylene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
Styrene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
Isopropylbenzene (Cumene)	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
n-Propylbenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
Bromobenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
2-Chlorotoluene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
4-Chlorotoluene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
1,3,5-Trimethylbenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
tert-Butylbenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
1,2,4-Trimethylbenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
sec-Butylbenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
p-Isopropyltoluene (Cymene)	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
1,2,3-Trimethylbenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
n-Butylbenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
1,2,4-Trichlorobenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
Hexachlorobutadiene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L



Sample Id: S-0002166073

Testing Parameter	Sample	Control	Result	Normalized Result	Units
Ann Arbor Chemistry Lab (Continued)					
1,2,3-Trichlorobenzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
Naphthalene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
Benzene	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L
Total Trihalomethanes	0.5	ND(0.5)	0.5	0.3	ug/L
Total Xylenes	ND(0.5)	ND(0.5)	ND(0.5)	ND(0.3)	ug/L

Sample Id: S-0002166075
Description: Subor GRP Pipe | 300mm ID x 6" L Pipe
Sampled Date: 10/16/2024
Received Date: 10/16/2024

Normalization Information:					
Testing Parameter	Sample	Control	Result	Normalized Result	Units
Ann Arbor Chemistry Lab					
Material Screening for Lead by XRF					
Lead content verification	Pass				



Testing Laboratories:

	Id	Address
All work performed at:	NSF_AA	NSF 789 N. Dixboro Road Ann Arbor MI 48105

References to Testing Procedures:

NSF Reference	Parameter / Test Description
C0513	Material Screening for Lead by XRF
C0743	* Acrylonitrile, Acetates and Acrylates by VOC GCMS
C1031	* Standard 61 Additives LAB SUM TEST Code
C1182	Metals I in water by ICPMS (Ref: EPA 200.8)
C2023	BASE/NEUTRAL/ACID EPA METHOD 625 modified Scan for Tentatively Identified Compounds (TICs)
C2024	Semivolatile Compounds, Base/Neutral/Acid Target 625 modified, Data Workup
C3050	Cobalt in Drinking Water by ICPMS (Ref: EPA 200.8)
C4022	* Acrylic Acid, LC/UV
C4357	* Phthalic Acids
C4662	Volatile Organic Compounds (Ref: EPA 524.2)

Test descriptions preceded by an asterisk “*” indicate that testing has been performed per NSF requirements but is not within its scope of accreditation.

Unless otherwise indicated, method uncertainties are not applied in any determinations of conformity. Testing utilizes the requested sections of any referenced standards, which may not be the entire standard.

Dates of Laboratory Activity: 23-OCT-2024 to 26-NOV-2024